



121 STATE STREET
ALBANY, NEW YORK 12207-1693
TEL: 518-436-0751
FAX: 518-436-4751

TO: **Memo Distribution List**

LeadingAge New York

FROM: Hinman Straub P.C.

RE: Statewide Emergency Regulations To Prevent Spread of Legionella

DATE: August 19, 2015

NATURE OF THIS INFORMATION: This is information explaining new requirements you need to be aware of or implement.

DATE FOR RESPONSE OR IMPLEMENTATION: The Emergency Regulations were adopted on August 17, 2015 and were effective immediately.

HINMAN STRAUB CONTACT PEOPLE: Sean Doolan and Michael Paulsen

THE FOLLOWING INFORMATION IS FOR YOUR FILING OR ELECTRONIC RECORDS:

Category: #4 Regulatory Process Suggested Key Word(s):

©2015 Hinman Straub P.C.

On August 17, 2015, the Public Health and Health Planning Council (PHHPC) and the Commissioner of Health adopted emergency regulations, effective immediately, to prevent the spread of *Legionella* bacteria by requiring registration, testing, inspection, and certification of cooling towers located in New York State. The regulations further require all Article 28 general hospitals and residential health care facilities (RHCs) to develop a Legionella sampling plan for its facilities' potable water distribution system and take necessary actions to protect the safety of their patients or residents. A copy of the emergency regulation is [attached](#).

As a result, all Article 28 general hospitals and RHCs located in New York State will be required to comply with the provisions contained in Section 4.11 of the emergency regulation (see Section 1 under Summary of Emergency Regulation). In addition, any facility that is the owner (corporation or other legal entity having a legal interest in, or control of, the Article 28 facility) of a cooling tower¹ will also be required to meet the registration, testing, and inspection, requirements contained in the emergency regulation by September 16, 2015.

Background

Recent outbreaks of legionellosis have been associated with cooling towers. Improper maintenance of cooling towers can contribute to the growth and dissemination of *Legionella* bacteria, the causative agent of legionellosis. Legionellosis causes cough, shortness of breath, high fever, muscle aches, headaches and can result in pneumonia. Hospitalization is often required, and between 5-30% of cases are fatal.

A cooling tower is an evaporative device that is part of a recirculated water system incorporated into a building's cooling, industrial process, refrigeration, or energy production system. Because water is part of the process of removing heat from a building, these devices require biocides—chemicals that kill or inhibit bacteria (including *Legionella*)—as means of controlling bacterial overgrowth. Overgrowth may result in the normal mists ejected from the tower having droplets containing *Legionella*.

In response to recent outbreaks of legionellosis in New York City, the Commissioner of Health and the PHHPC have adopted emergency regulations, under their authority to adopt regulations when necessary for the preservation of the public health, safety or general welfare. The emergency regulations have been adopted to prevent the spread of *Legionella* bacteria and protect the public from future outbreaks of Legionnaires' disease.

Summary of Emergency Regulation

1. Requirements for All Article 28 General Hospitals and RHCs in New York State

The emergency regulations contain a provision applicable to all Article 28 general hospitals and RHCs in New York State, regardless of whether the facility owns or operates a cooling tower

¹ The term "cooling tower" means a cooling tower, evaporative condenser or fluid cooler that is part of a recirculated water system incorporated into a building's cooling, industrial process, refrigeration or energy production system.

on its premises. Specifically, the emergency regulations require that all Article 28 general hospitals and RHCs:

- Adopt a Legionella sampling plan for its facilities' potable water distribution system;
- Report the results of such sampling conducted pursuant to the adopted sampling plan; and
- Take necessary responsive actions to protect the safety of their patients or residents.

The emergency regulations currently do not identify the process for general hospitals and RHCs to report the results of sampling its facilities' potable water distribution system. It is possible that this reporting will be conducted through the statewide electronic system that will be used for registering cooling towers to be developed by the Department of Health (DOH). The regulation requires DOH to investigate whether more stringent requirements for general hospitals and RHCs are warranted.

It is important to note that at this time, the emergency regulation does not require Article 28 diagnostic and treatment centers (D&TCs) to meet the requirements contained in this regulation. However, if a licensed D&TC owns a building that uses a cooling tower, the requirements identified in Section 2 of this memorandum would apply.

2. Requirements for Facilities in New York State That Own A Cooling Tower

In addition to the mandatory sampling and reporting of a facilities' potable water distribution system, any facility that owns a cooling tower would be subject to additional requirements contained in the emergency regulation. The requirements identified in this section only apply to the owners of buildings and facilities in New York State that operate a cooling tower.

a. Registration

Any owner of a building with an existing cooling tower must electronically register the tower with the Department of Health by September 16, 2015 (30 days following the enactment of the emergency regulation). All new cooling towers must be registered prior to initial operation. There is no cost to register a cooling tower with the State.

b. Culture Sample Collection and Testing

Any owner of a building with a cooling tower must collect samples and obtain culture testing within the next 30 days. Thereafter, testing must be performed every 90 days, or in accordance with a maintenance program and plan prepared by the building owner. The owner is required to take immediate actions in response to such testing as specified in the plan, including interpreting Legionella culture results. Owners are required to clean and disinfect any cooling tower that is shut down for more than five days.

In the event the results of the culture testing require cleaning and disinfection of the cooler tower, the owner may only use a commercial pesticide applicator or pesticide technician who is qualified to apply biocide in a cooling tower and certified in accordance with the requirements of Article 33 of the Environmental Conservation Law and 6 NYCRR Part 325, or a pesticide apprentice under the supervision of a certified applicator. Further, only biocide products

registered by the New York State Department of Environmental Conservation may be used in disinfection.

c. Inspection and Certification

All cooling towers must be inspected within the next 30 days, unless such tower has been inspected within the last 30 days (on or after July 18, 2015). Following the initial inspection, all cooling towers must be inspected at intervals not exceeding every 90 days while in use. All inspections must be performed by a: New York State licensed professional engineer; certified industrial hygienist; certified water technologist; or environmental consultant with training and experience performing inspections in accordance with current standard industry protocols.

All cooling towers must be certified as complying with all regulatory requirements by November 1, 2016, and thereafter annually by November 1 of each year. The certification must provide that such cooling tower was inspected, tested, cleaned, and disinfected in compliance with the emergency regulation, that the condition of the cooling tower is appropriate for its intended use, and that a maintenance program and plan has been developed and implemented by the owner.

d. Maintenance Program

Any owner of a building with a cooling tower must implement a maintenance program and plan by March 1, 2016, developed in accordance with developed in accordance with section 7.2 of Legionellosis: Risk Management for Building Water Systems (ANSI/ASHRAE 188-2015), 2015 edition with final approval date of June 26, 2015. The plan must include a schedule for routine sampling, as well as procedures for emergency testing and disinfection to destroy Legionella bacteria. Owners must maintain a copy of the plan on the premises where a cooling tower is located.

e. Recordkeeping

All owners are required to maintain records of all inspection findings, deficiencies, corrective actions, cleaning and disinfection, tests, and certifications for at least three years. In addition, an owner is required to maintain a copy of the maintenance program and plan on the premises where a cooling tower is located.

f. Electronic Registration and Reporting

All owners of buildings and facilities in New York State that operate a cooling tower will be required to electronically register their tower by September 16, 2015. In addition to registration, all actions required by the regulations must be reported to the electronic system within 10 days of such actions being taken.

Please contact us with any questions that you may have.

Pursuant to the authority vested in the Public Health and Health Planning Council and the Commissioner of Health by section 225(5)(a) of the Public Health Law, Part 4 of Title 10 (Health) of the Official Compilation of Codes, Rules and Regulations of the State of New York is added, to be effective upon filing with the Secretary, to read as follows:

4.1 Scope.

All owners of cooling towers, and all general hospitals and residential health care facilities as defined in Article 28 of the Public Health Law, shall comply with this Part.

4.2 Definitions.

As used in this Part, the following terms shall have the following meanings:

(a) Building. The term “building” means any structure used or intended for supporting or sheltering any use or occupancy. The term shall be construed as if followed by the phrase “structure, premises, lot or part thereof” unless otherwise indicated by the text.

(b) Commissioner. The term “commissioner” means the New York State Commissioner of Health.

(c) Cooling Tower. The term “cooling tower” means a cooling tower, evaporative condenser or fluid cooler that is part of a recirculated water system incorporated into a building’s cooling, industrial process, refrigeration or energy production system.

(d) Owner. The term “owner” means any person, agent, firm, partnership, corporation or other legal entity having a legal or equitable interest in, or control of the premises.

4.3 Registration.

All owners of cooling towers shall register such towers with the department within 30 days after the effective date of this Part. Thereafter, all owners of cooling towers shall register such towers with the department prior to initial operation, and whenever any owner of the cooling tower changes. Such registration shall be in a form and manner as required by the commissioner and shall include, at a minimum, the following information:

- (a) street address of the building at which the cooling tower is located, with building identification number, if any;
- (b) intended use of the cooling tower;
- (c) name(s), address(es), telephone number(s), and email address(es) of all owner(s) of the building;
- (d) name of the manufacturer of the cooling tower;
- (e) model number of the cooling tower;
- (f) specific unit serial number of the cooling tower;
- (g) cooling capacity (tonnage) of the cooling tower;
- (h) basin capacity of the cooling tower;
- (i) whether systematic disinfection is maintained manually, through timed injection, or through continuous delivery;
- (j) the contractor or employee engaged to inspect and certify the cooling tower; and
- (k) commissioning date of the cooling tower.

4.4 Culture sample collection and testing; cleaning and disinfection.

- (a) All owners of cooling towers shall collect samples and obtain culture testing:

(1) within 30 days of the effective date of this Part, unless such culture testing has been obtained within 30 days prior to the effective date of this Part, and shall take immediate actions in response to such testing, including interpreting Legionella culture results, if any, as specified in Appendix 4-A.

(2) in accordance with the maintenance program and plan, and shall take immediate actions in response to such testing as specified in the plan, including interpreting Legionella culture results, if any, as specified in Appendix 4-A; provided that if a maintenance program and plan has not yet been obtained in accordance with section 4.6 of this Part, bacteriological culture samples and analysis (dip slides or heterotrophic plate counts) to assess microbiological activity shall be obtained, at intervals not exceeding 90 days while the tower is in use, and any immediate action in response to such testing shall be taken, including interpreting Legionella culture results, if any, as specified in Appendix 4-A.

(b) Any person who performs cleaning and disinfection shall be a commercial pesticide applicator or pesticide technician who is qualified to apply biocide in a cooling tower and certified in accordance with the requirements of Article 33 of the Environmental Conservation Law and 6 NYCRR Part 325, or a pesticide apprentice under the supervision of a certified applicator.

(c) Only biocide products registered by the New York State Department of Environmental Conservation may be used in disinfection.

(d) All owners shall ensure that all cooling towers are cleaned and disinfected when shut down for more than five days.

4.5 Inspection and certification.

(a) Inspection. All owners of cooling towers shall inspect such towers within 30 days of the effective date of this Part, unless such tower has been inspected within 30 days prior to the effective date of this Part. Thereafter, owners shall ensure that all cooling towers are inspected at intervals not exceeding every 90 days while in use. All inspections shall be performed by a: New York State licensed professional engineer; certified industrial hygienist; certified water technologist; or environmental consultant with training and experience performing inspections in accordance with current standard industry protocols including, but not limited to ASHRAE 188-2015, as incorporated by section 4.6 of this Part.

(1) Each inspection shall include an evaluation of:

- (i) the cooling tower and associated equipment for the presence of organic material, biofilm, algae, and other visible contaminants;
- (ii) the general condition of the cooling tower, basin, packing material, and drift eliminator;
- (iii) water make-up connections and control;
- (iv) proper functioning of the conductivity control; and
- (v) proper functioning of all dosing equipment (pumps, strain gauges).

(2) Any deficiencies found during inspection will be reported to the owner for immediate corrective action. A person qualified to inspect pursuant to paragraph (a) of this section shall document all deficiencies, and all completed corrective actions.

(3) All inspection findings, deficiencies, and corrective actions shall be reported to the owner, recorded, and retained in accordance with this Part, and shall also be reported to the department in accordance with section 4.10 of this Part.

(b) Certification. Each year, the owner of a cooling tower shall obtain a certification from a person identified in paragraph (a) of this section, that such cooling tower was inspected, tested, cleaned, and disinfected in compliance with this Part, that the condition of the cooling tower is appropriate for its intended use, and that a maintenance program and plan has been developed and implemented as required by this Part. Such certification shall be obtained by November 1, 2016, and by November 1 of each year thereafter. Such certification shall be reported to the department.

4.6 Maintenance program and plan.

(a) By March 1, 2016, and thereafter prior to initial operation, owners shall obtain and implement a maintenance program and plan developed in accordance with section 7.2 of Legionellosis: Risk Management for Building Water Systems (ANSI/ASHRAE 188-2015), 2015 edition with final approval date of June 26, 2015, at pages 7-8, incorporated herein by reference. The latest edition of ASHRAE 188-2015 may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400, or toll free 1-800-527-4723. Copies are available for inspection and copying at: Center for Environmental Health, Corning Tower Room 1619, Empire State Plaza, Albany, NY 12237.

(b) In addition, the program and plan shall include the following elements:

- (1) a schedule for routine bacteriological sampling and analysis (dip slides or heterotrophic plate counts) to assess microbiological activity and a schedule for Legionella sampling and culture analysis; provided that where the owner is a general hospital or residential health care facility, as defined in Article 28 of the Public Health

Law, routine testing shall be performed at a frequency in accordance with the direction of the department.

(2) emergency sample collection and submission of samples for Legionella culture testing to be conducted in the case of events including, but not limited to:

- (i) power failure of sufficient duration to allow for the growth of bacteria;
- (ii) loss of biocide treatment sufficient to allow for the growth of bacteria;
- (iii) failure of conductivity control to maintain proper cycles of concentration;
- (iv) a determination by the commissioner that one or more cases of legionellosis is or may be associated with the cooling tower, based upon epidemiologic data or laboratory testing; and
- (v) any other conditions specified by the commissioner.

(3) immediate action in response to culture testing, including interpreting Legionella culture results, if any, as specified in Appendix 4-A; provided that where the owner is a general hospital or residential health care facility, as defined in Article 28 of the Public Health Law, the provisions shall additionally require immediately contacting the department for further guidance, but without any delay in taking any action specified in Appendix 4-A.

(c) An owner shall maintain a copy of the plan required by this subdivision on the premises where a cooling tower is located. Such plan shall be made available to the department or local health department immediately upon request.

4.7 Recordkeeping.

An owner shall keep and maintain records of all inspection findings, deficiencies, corrective actions, cleaning and disinfection, and tests performed pursuant to this Part, and certifications, for at least three years. An owner shall maintain a copy of the maintenance program and plan required by this Part on the premises where a cooling tower is located. Such records and plan shall be made available to the department or local health department immediately upon request.

4.8 Discontinued use.

The owner of a cooling tower shall notify the department within 30 days after removing or permanently discontinuing use of a cooling tower. Such notice shall include a statement that such cooling tower has been disinfected and drained in accordance with the same procedures as set forth in the shutdown plan, as specified in the maintenance program and plan required pursuant to this Part.

4.9 Enforcement.

(a) An officer, employee or agent of the department or local health department may enter onto any property to inspect the cooling tower for compliance with the requirements of this Part, in accordance with applicable law.

(b) Where an owner does not register, obtain certification, clean or disinfect, culture test or inspect a cooling tower within the time and manner set forth in this Part, the department or local health department may determine that such condition constitutes a nuisance and may take such action as authorized by law. The department or local health department may also take any other action authorized by law.

(c) A violation of any provision of this Part is subject to all civil and criminal penalties as provided for by law. Each day that an owner remains in violation of any provision of this Part shall constitute a separate and distinct violation of such provision.

4.10 Electronic registration and reporting.

(a) (1) Within 30 days of the effective date of this Part, and thereafter within 10 days after any action required by this Part, owners shall electronically input the following information in a statewide electronic system designated by the commissioner:

- (i) registration information;
- (ii) date of last routine culture sample collection, sample results, and date of any required remedial action;
- (iii) date of any legionella sample collection, sample results, and date of any required remedial action;
- (iv) date of last cleaning and disinfection;
- (v) dates of start and end of any shutdown for more than five days;
- (vi) date of last certification and date when it was due;
- (vii) date of last inspection and date when it was due;
- (viii) date of discontinued use; and
- (ix) such other information as shall be determined by the department.

(2) The commissioner may suspend this requirement in the event that the electronic system is not available.

(b) The data in the system referenced in paragraph (a) shall be made publicly available, and shall be made fully accessible and searchable to any local health department. Nothing in this Part shall

preclude a local health department from requiring registration and reporting with a local system or collecting fees associated with the administration of such system.

4.11 Health care facilities

(a) All general hospitals and residential health care facilities, as defined in Article 28 of the Public Health Law, shall, as the department may determine appropriate:

- (1) adopt a Legionella sampling plan for its facilities' potable water distribution system;
- (2) report the results of such sampling; and
- (3) take necessary responsive actions.

(b) With respect to such general hospitals and residential health care facilities, the department shall investigate to what extent, if any, requirements more stringent than those set forth in this Part are warranted.

4.12 Severability.

If any provisions of this Part or the application thereof to any person or entity or circumstance is adjudged invalid by a court of competent jurisdiction, such judgment shall not affect or impair the validity of the other provisions of this Part or the application thereof to other persons, entities, and circumstances.

Appendix 4-A

Interpretation of Legionella Culture Results from Cooling Towers	
Legionella Test Results in CFU ¹ /ml	Approach

No detection (< 10 CFU /ml)	Maintain treatment program and <i>Legionella</i> monitoring.
For levels at ≥ 10 CFU /ml but < 1000 CFU /ml perform the following:	<ul style="list-style-type: none"> ○ Review treatment program. ○ Institute immediate <u>online disinfection</u>² to help with control ○ Retest the water in 3 – 7 days. <ul style="list-style-type: none"> ▪ Continue to retest at the same time interval until two consecutive readings show acceptable improvement, as determined by a person identified in 10 NYCRR 4.6. Continue with regular maintenance strategy. ▪ If < 100 CFU /ml repeat <u>online disinfection</u>² and retest. ▪ If ≥ 100 CFU /ml but < 1000 CFU /ml further investigate the water treatment program and immediately perform <u>online disinfection</u>.² Retest and repeat attempts at control strategy. ○ If ≥ 1000 CFU /ml undertake control strategy as noted below.
For levels ≥ 1000 CFU /ml perform the following:	<ul style="list-style-type: none"> ○ Review the treatment program ○ Institute immediate <u>online decontamination</u>³ to help with control ○ Retest the water in 3 – 7 days. <ul style="list-style-type: none"> ▪ Continue to retest at the same time interval until two consecutive readings show acceptable improvement, as determined by a person identified in 10 NYCRR 4.6. Continue with regular maintenance strategy. ▪ If < 100 CFU /ml repeat <u>online disinfection</u>² and retest;

	<ul style="list-style-type: none"> ▪ If ≥ 100 CFU /ml but < 1000 CFU /ml further investigate the water treatment program and immediately perform <u>online disinfection</u>.² Re-test and repeat attempts at control strategy. ▪ If ≥ 1000 CFU /ml carry out <u>system decontamination</u>⁴
--	---

¹ Colony forming units.

² Online disinfection means – Dose the cooling tower water system with either a different biocide or a similar biocide at an increased concentration than currently used.

³ Online decontamination means – Dose the recirculation water with a chlorine-based compound equivalent to at least 5 mg/l (ppm) free residual chlorine for at least one hour; pH 7.0 to 7.6.

⁴ System decontamination means – Maintain 5 to 10 mg/l (ppm) free residual chlorine for a minimum of one hour; drain and flush with disinfected water; clean wetted surface; refill and dose to 1 – 5 mg/l (ppm) of free residual chlorine at pH 7.0 – 7.6 and circulate for 30 minutes. Refill, re-establish treatment and retest for verification of treatment.

A Regulatory Impact Statement, Regulatory Flexibility Analysis, Rural Area Flexibility Analysis and Job Impact Statement will be published in the Register within 30 days of the rule's effective date.

Emergency Justification

Improper maintenance of cooling towers can contribute to the growth and dissemination of *Legionella* bacteria, the causative agent of legionellosis. Legionellosis causes cough, shortness of breath, high fever, muscle aches, headaches and can result in pneumonia. Hospitalization is often required, and between 5-30% of cases are fatal. People at highest risk are those 50 years of age or older, current or former smokers, those with chronic lung diseases, those with weakened immune systems from diseases like cancer, diabetes, or kidney failure, and those who take drugs to suppress the immune system during chemotherapy or after an organ transplant. The number of cases of legionellosis reported in New York State between 2005-2014 increased 323% when compared to those reported in the previous ten year period.

Outbreaks of legionellosis have been associated with cooling towers. A cooling tower is an evaporative device that is part of a recirculated water system incorporated into a building's cooling, industrial process, refrigeration, or energy production system. Because water is part of the process of removing heat from a building, these devices require biocides—chemicals that kill or inhibit bacteria (including *Legionella*)—as means of controlling bacterial overgrowth. Overgrowth may result in the normal mists ejected from the tower having droplets containing *Legionella*.

For example, in 2005, a cooling tower located at ground level adjacent to a hospital in New Rochelle, Westchester County resulted in a cluster of 19 cases of legionellosis and multiple fatalities. Most of the individuals were dialysis patients or companions escorting the patients to their dialysis session. One fatality was in the local neighborhood. The cooling tower was found to have insufficient chemical treatment. The entire tower was ultimately replaced by the

manufacturer in order to maintain cooling for the hospital and to protect public health. In June and July of 2008, 12 cases of legionellosis including one fatality were attributed to a small evaporative condenser on Onondaga Hill in Syracuse, Onondaga County. An investigation found that the unit was not operating properly and this resulted in the growth of microorganisms in the unit. Emergency biocide treatment was initiated and proper treatment was maintained. No new cases were then detected thereafter.

Recent work has shown that sporadic cases of community legionellosis are often associated with extended periods of wet weather with overcast skies. A study conducted by the New York State Department of Health that included data from 13 states and one United States municipality noted a dramatic increase in sporadic, community acquired legionellosis cases in May through August 2013. Large municipal sites such as Buffalo, Erie County reported 2- to 3-fold increases in cases without identifying common exposures normally associated with legionellosis. All sites in the study except one had a significant correlation, with some time lag, between legionellosis case onset and one or more weather parameters. It was concluded that large municipalities produce significant mist (droplet) output from hundreds of cooling towers during the summer months. Periods of sustained precipitation, high humidity, cloud cover, and high dew point may lead to an “urban cooling tower” effect. The “urban cooling tower” effect is when a metropolitan area with hundreds of cooling towers acts as one large cooling tower producing a large output of drift, which is entrapped by humid air and overcast skies.

More recently, 119 cases of legionellosis that included 12 fatalities (8/12/15) occurred in Bronx, NY (July-August, 2015). This event was preceded by an outbreak in Co-Op City in the Bronx, from December 2014 to January 2015, which involved 8 persons and no fatalities. Both of these outbreaks have been attributed to cooling towers, and emergency disinfection of

compromised towers helped curtail these outbreaks. These events highlight the need for proper maintenance of cooling towers.

The heating, ventilation, and air-conditioning (HVAC) industry has issued guidelines on how to seasonally start a cooling tower; treat it with biocides and other chemicals needed to protect the components from scale and corrosion; and set cycles of operations that determine when fresh water is needed; and how to shut down the tower at the end of the cooling season. The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) has recently released a new Standard entitled *Legionellosis: Risk Management for Building Water Systems* (ANSI/ASHRAE Standard 188-2015). Section 7.2 of that document outlines components of the operations and management plan for cooling towers. The industry also relies on other guidance for specific treatment chemicals, emergency disinfection or decontamination procedures and other requirement.

However, none of the guidance is obligatory. Consequently, poor practice in operation and management can result in bacterial overgrowth, increases in legionellae, and mist emissions that contain a significant dose of pathogenic legionellae. This regulation requires that all owners of cooling towers ensure proper maintenance of the cooling towers, to protect the public and address this public health threat.

Further, these regulations require all general hospitals and residential health care facilities (i.e., nursing homes) to develop a sampling plan, report the results, and take necessary actions to protect the safety of their patients or residents. The details of each facility's sampling plan and remedial measures will depend on the risk factors for acquiring Legionnaires' disease in the

population served by the hospital or nursing home.

Most people in nursing homes should be considered at risk, as residents are typically over 50 years of age. In general hospitals, persons at risk include those over 50 years of age, as well as those receiving chemotherapy, those undergoing transplants, and other persons housed on healthcare units that require special precautions. Additional persons who might be at increased risk for acquiring Legionnaires' disease include persons on high-dose steroid therapy and persons with chronic lung disease. Certain facilities with higher risk populations, such as those with hematopoietic stem-cell transplant (HSCT) and solid organ transplant units, require more protective measures.

An environmental assessment involves reviewing facility characteristics, hot and cold water supplies, cooling and air handling systems and any chemical treatment systems. The purpose of the assessment is to discover any vulnerabilities that would allow for amplification of *Legionella* spp. and to determine appropriate response actions in advance of any environmental sampling for *Legionella*. Initial and ongoing assessment should be conducted by a multidisciplinary team that represents the expertise, knowledge and functions related to the facility's operation and service. A team should include, at a minimum, representatives from the following groups: Infection Control; Physical Facilities Management; Engineering; Clinicians; Laboratory; and Hospital Management.

Thus, to protect the public from the immediate threat posed by *Legionella*, the Commissioner of Health and the Public Health and Health Planning Council have determined it necessary to file these regulations on an emergency basis. Public Health Law § 225, in

conjunction with State Administrative Procedure Act § 202(6) empowers the Council and the Commissioner to adopt emergency regulations when necessary for the preservation of the public health, safety or general welfare and that compliance with routine administrative procedures would be contrary to the public interest.